#### **STREAMING APPLICATIONS OF HFC-227ea**

Mark L. Robin Fluorine Chemicals Division Great Lakes Chemical Corporation West Lafayette, IN 47906 **USA**  Ernest E. Ellis Metalcraft, Inc. Baltimore, MD 21237 USA

While significant progress has been made towards the replacement of Halon 1301 in total flooding fire suppression applications, far less progress has been made in the development of viable alternatives for streaming applications. We report here the development of a novel, zero **ODP** portable extinguishing system; this novel design has resulted in a great enhancement of the performance of HFC-227ea in streaming applications. Most recently, employment of the unit has allowed for the achievement of a UL 5BC rating for a unit containing 5.75 lbs of HFC-227ea. The attainment of a 5BC rating renders the unit potentially attractive for use in aircraft cabins, where current **FAA** requirements call for a minimum 5BC rating. We report here the further development of this novel extinguishing unit, including its performance in Underwriters Laboratories tests, ground-based military applications, and commercial aircraft applications.

## Streaming Agents: HCFC-123

- Scheduled for phase-out due to non-zero ODP
- Potent Cardiac Sensitizer
  - ✓ NOAEL = 1 % vlv
  - $\checkmark$  LOAEL = 2 % v/v
- Increased incidence of benign tumors in chronic studies
- Toxicity concerns led to further investigations
  - ✓ C<sub>4</sub> through C<sub>6</sub> Perfluorocarbons

#### Perfluorohexane

- Atmospheric Lifetime = 3100 years
- **HGWP = 5200** (100 year ITH)
- No production bans
- SNAP guidelines restrict use to applications where no other alternatives are technically feasible due to safety or performance requirements

#### Streaming Agents: Previous Studies

- Air Force Groups Meeting at Tyndall AFB April 1994
- Concluded no near-term candidate was completely acceptable
- Air Force would retain Halon 1211 until a suitable replacement became available

## Streaming Agent Candidates

- Requirement for clean extinguishment restricts choice to halogenated agents and inert gases
- Storage volume requirements prohibit practical use of inert gases
- Among the halocarbons, only HFCs and **PFCs** not subject to phaseout

Streaming Agent Comparison:	
<b>Restrictions and Phaseout</b>	

Agent	Tradename	Subject to Use Restrictions?	
HCFC-123	FE-232	nu	yes
HCFC Blend B	Halotron I	nu	yes
HCFC Blend C	NAP P-III	no	yes
HCFC Blend D	NAF Blitz	no	yes
HCFC-124	FE-234	no	yes
PFC-5-1-14	CEA-614	yes	nu
HFC-236fa	FE-36	proposed	no
HFC-227ea	FM-200	no	no

# Streaming Performance of HFC-227ea

- In general, low boiling agents more suitable for total flooding applications
- MetalCraft/Great Lakes Chemical
  - ✓ joint development of novel extinguisher
  - ✓ enhanced streaming performance
  - ✓ UL 2B rating achieved for 2.5 lb unit
  - ∠ UL 3B rating achieved for 3.0 lb unit
  - ✓ UL 5B rating achieved for 5.7 lb unit

# UL Testing of MetalCraft/GLCC 2.5 lb Unit

Fire Type	2B	2B	2B	2B
Fire size (ft <sup>2</sup> )	5	5	5	5
Preburn (s)	60	60	60	60
Conditioning	normal	nermal	normal	-40 'F
Pressurization (psig)	360	360	360	360
Agent Discharge (lb)	1.7	1.6	2.0	1.6

treaming Agents: UL Ratings					
		Age	nt Re	quirement	( <b>lb</b> )
			I	Rating	
Agent	2BC	3BC	5BC	1A:10B(	2A:10BC
Halotron I					
(HCFC-123)	2.5	-	5	12	20
Cleanguard					
(HFC-236fa)	-	-	6	10	14
FM-200					
(HFC-227ea)	2.5	3	5.7	TBD	TBD

