



NEXTENERGY

ask us what's next





NIST Workshop On Power Conditioning System Architectures For Plugin-Vehicle Fleets As Grid Storage

How Might A PEV Fleet Aid In Integration Of Resilient Micro-Grids?
(Storage Functions To Support Resilient Micro-Grids)

Bill Siddall, Director, NextEnergy

What Size Is The Micro-Grid?

The size of the grid, the amount of generation and load, matters to the effectiveness of individual and aggregated Plug-in Electric Vehicles (PEVs).

Forward Operating Base Simulation
Fort Irwin, CA



60kW to 200kW

Wright-Patterson AFB
Dayton, OH



20MW to 80MW



Benefits, Maximum Market Potential, and Maximum Economic Value

Trade-Offs

#	Benefit Type	Benefit (\$/kW)**		Potential MW, 10 Years)		Economy (\$Million) [†]	
		Low	High	CA	U.S.	CA	U.S.
1	Electric Energy Time-shift	400	700	1,445	18,417	795	10,129
2	Electric Supply Capacity	359	710	1,445	18,417	772	9,838
3	Load Following	600	1,000	2,889	36,834	2,312	29,467
4	Area Regulation	785	2,010	80	1,012	112	1,415
5	Electric Supply Reserve Capacity	57	225	636	5,986	90	844
6	Voltage Support	400		722	9,209	433	5,525
7	Transmission Support	192		1,084	13,813	208	2,646
8	Transmission Congestion Relief	31	141	2,889	36,834	248	3,168
9.1	T&D Upgrade Deferral 50th percentile ^{††}	481	687	386	4,986	226	2,912
9.2	T&D Upgrade Deferral 90th percentile ^{††}	759	1,079	77	997	71	916
10	Substation On-site Power	1,800	3,000	20	250	47	600



Standard Assumption Values for Storage Power

Trade-Offs

#	Type	Storage Power		
		Low	High	Note
1	Electric Energy Time-shift	1 MW	500 MW	Low per ISO transaction min. (Can aggregate smaller capacity.) High = combined cycle gen.
2	Electric Supply Capacity	1 MW	500 MW	Same as above.
3	Load Following	1 MW	500 MW	Same as above.
4	Area Regulation	1 MW	40 MW	Low per ISO transaction min. Max is 50% of estimated CA technical potential of 80 MW.
5	Electric Supply Reserve Capacity	1 MW	500 MW	Low per ISO transaction min. (Can aggregate smaller capacity.) High = combined cycle gen.
6	Voltage Support	1 MW	10 MW	Assume distributed deployment, to serve Voltage support needs locally.
7	Transmission Support	10 MW	100 MW	Low value is for subtransmission.
8	Transmission Congestion Relief	1 MW	100 MW	Low per ISO transaction min. (Can aggregate smaller capacity.) High = 20% of high capacity transmission.
9.1	T&D Upgrade Deferral 50th percentile	250 kW	5 MW	Low = smallest likely, High = high end for distribution & subtransmission.
9.2	T&D Upgrade Deferral 90th percentile	250 kW	2 MW	Same as above.
10	Substation On-site Power	1.5 kW	5 kW	Per EPRI/DOE Substation Battery Survey.
11	Time-of-use Energy Cost Management	1 kW	1 MW	Residential to medium sized commercial/industrial users



Standard Assumption Values for Discharge Duration

Trade-Offs

*Hours unless indicated otherwise. Min. = minutes. Sec. = Seconds.

#	Type	Discharge Duration*		
		Low	High	Note
1	Electric Energy Time-shift	2	8	Depends on energy price differential, storage efficiency, and storage variable operating cost.
2	Electric Supply Capacity	4	6	Peak demand hours
3	Load Following	2	4	Assume: 1 hour of discharge duration provides approximately 2 hours of load following.
4	Area Regulation	15 min.	30 min.	Based on demonstration of Beacon Flywheel.
5	Electric Supply Reserve Capacity	1	2	Allow time for generation-based reserves to come on-line.
6	Voltage Support	15 min.	1	Time needed for a) system stabilization or b) orderly load shedding.
7	Transmission Support	2 sec.	5 sec.	Per EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications.[17]
8	Transmission Congestion Relief	3	6	Peak demand hours. Low value is for "peaky" loads, high value is for "flatter" load profiles.



PEV Fleet Characteristics

Organizational Control Of Fleet Designs and Operations

- Vehicle Specification: PEV Balance of Parts' Design as presented by Original Equipment Manufacturer (OEM)
- Vehicle Location: Operational requirements when PEV is not a micro-grid storage device
- Vehicle Service Time: Operational duty cycle compatibility with micro-grid duty cycle.



Micro-Grid Storage Application Recommendations

Application	Definition	Power	Duration	Response	Location of Storage	Use Description	Application Element
Regulation of Voltage & Frequency	second-by-second power balancing to regulate frequency	1-2% of system max	up to 5 min.	<10 sec.	Sub-Station	"Short Term" Power Quality maintenance Ideal PEV Fleet Application	Voltage Support
			15 - 30 min	< 10 sec			Transmission Support
				Electric Service Reliability			
Spinning Reserve Reduction/ Load Following	Displace reserve generation asset with storage	8-12% of load	5 to 30 min.	<10 sec.	Sub-Station / Peaker Plant location		Electric Service Power Quality
			15 - 30 min				Wind Gen. Grid Integration (short duration)
T&D Deferral/Load Profile Management (Transmission & Distribution)	Delay investing in transmission & distribution infrastructure by storing energy for peak periods	XX% of max load	up to 12 hrs	10 to 30 min.	Sub-Station / Peaker Plant location		Distributed Load Management Some PEV Fleet Application
			hours				
Peaking Generation/ Deferral						Electric Supply Reserve Capacity	
Arbitrage	Buy-low-sell-high on energy cost	depends on business case up to 12 hrs.		10 to 30 min.	Peaker Plant /Generator location	T&D Upgrade Deferral 50th Percentile	
			1 hr				
						Transmission Congestion Relief	
Diurnal or Longer Load Profile Management	Matching generation profiles of AE source to daily or longer load	relative to % of AE sources	12 hours or longer (6-12 hrs)	30 min.	AE site location	Bulk Energy Storage No PEV Fleet Application	Electric Supply Capacity
							Electric Energy Time Shift
							Time of Use Energy Cost Management
							Demand Charge Management
							Renewables Capacity Firming
							Renewables Energy Time Shift
							Wind Generation Grid Integration: long duration



PEV Fleet Considerations In Support of Micro-Grids

In Summary:

- Micro-Grid Size
- PEV Design from OEMs
- Benefits Trade-Offs
- Application Suitability

