

Air Emissions Management at NIST-Boulder

NIST S 7301.03

Approval Date: 11/19/2025

Effective Date¹: 11/19/2025

1. PURPOSE

The purpose of this suborder is to communicate to all responsible parties the regulatory and permit requirements that NIST will comply with regarding the emission of air pollutants from the NIST-Boulder Site.

2. BACKGROUND

Under Colorado Air Quality Control Commission regulations (5 CCR 1001), the owners or operators of equipment emitting air pollutants, *i.e.*, sources, are required to obtain a permit to emit air pollutants from existing sources or construct new sources. Permitting requirements are based on the quantity and types of pollutants emitted. The fuel consumption or power produced by a source is commonly a *de facto* means of calculating emissions and determining if an Air Pollutant Emission Notice (APEN) form must be submitted to the Colorado Department of Public Health and Environment (CDPHE).

Permit categories are determined based on the quantities of pollutants emitted. Sites with emissions less than 25,000 tons of criteria pollutants (*e.g.*, carbon monoxide, nitrogen oxides, sulfur oxides, particulate matter, volatile organic compounds) and 10 tons of hazardous air pollutants (HAPs) are required to apply for a “construction permit” to construct sources and emit pollutants. Due to the Front Range area, including the Denver metropolitan area, being designated as a severe nonattainment area for ozone, NIST-Boulder is limited to emitting less than 25 tons of nitrogen oxides (NO_x) per year. Hazardous air pollutants are identified in Appendix B of the Colorado Air Quality Control Commission Regulations (5 CCR 1001-5). Sites emitting quantities greater than those listed above are required to apply for a permit under Title V of the Clean Air Act. As NIST-Boulder has air pollutant emissions sources having the combined potential to emit more than 25 tons of NO_x per year, NIST is permitted as a synthetic minor source required to limit emissions to the quantities of NO_x identified in the permit.

¹ The revision history for this document can be found in Appendix A.

38 The NIST-Boulder site operates seven boilers, seven diesel-fired emergency generators,
39 eleven natural gas-fired emergency generators, and six natural gas-fired water heaters
40 permitted by the CDPHE, regulated as synthetic minor source. A “Construction Permit”
41 (permit number 09BO0159, referred to as “the permit”) was issued on May 28, 2009. It has
42 been re-issued multiple times, most recently on October 22, 2025, identifying NIST-Boulder
43 as a synthetic minor source. The sources are identified in Table 6.1 and Appendix B. The
44 permit is a vehicle for communicating regulatory requirements to NIST.

45
46 The NIST-WWV/WWVB facility does not have any sources of air pollutant emissions
47 exceeding the threshold at which the submission of an APEN form is required (See Section
48 6.a.(1)(b) and (c) below).

49
50

51 3. APPLICABILITY

- 52 a. The provisions of this suborder apply to all NIST-Boulder workplaces and to all NIST
53 employees and covered associates on the Boulder site who may cause the generation of
54 regulated air pollutants from an existing, new, or proposed source.
- 55
- 56 b. The provisions of this suborder apply to existing, new, and proposed air pollutant sources
57 including boilers, emergency generators, portable asphalt melting/mixing equipment, and
58 other sources of volatile organic compounds.
- 59
- 60 c. In general, micro- or bench-scale laboratory activities at NIST-Boulder are exempt from
61 federal and state regulatory requirements and the provisions of this suborder. However, air
62 emissions should be minimized from all sources. Any questions regarding air emissions shall
63 be directed to the NIST Boulder Safety, Health, and Environment Division (BSHED), x5375,
64 Option 3.
- 65
- 66 d. The provisions of this suborder do not apply to mobile sources such as motor vehicles,
67 exhaust from construction equipment, *etc.*

68
69

70 4. REFERENCES

71 Requirements common to all NIST Environmental Suborders can be found in Section 4 of
72 NIST O 7301.00. The requirements specific to this suborder are as follows:

73
74

- 74 a. [Colorado Air Quality Control Commission Regulations](#), 5 CCR 1001-1 through 23.
- 75
- 76 b. [40 CFR Chapter I, Subchapter C, Air Programs](#).

77

78 c. [Mile High Flood District Urban Storm Drainage Criteria Manual](#), Volume 3.

79

80 d. [NIST Boulder \(Synthetic Minor\) Construction Permit 09BO0159](#).

81

82 e. [NIST Boulder Operations and Maintenance \(O&M\) Plan](#).

83

84

85 **5. APPLICABLE NIST DIRECTIVES**

86 Other NIST Environmental Suborders applicable to work covered by this suborder include
87 the following:

88

89 a. NIST S 7101.23: [Safety Education and Training](#)

90

91 b. NIST S 7301.01: [Environmental Management System](#)

92

93

94 **6. REQUIREMENTS**

95 a. General Requirements

96

97 (1) New Project Review/Identification of Permitting Requirements

98

99 (a) The contracting officer representative for any project installing a boiler or emergency
100 generator shall:

101

102 i. Complete the [Project Planning Environmental Checklist](#); and

103

104 ii. Provide notification to BSHED allowing 15 business days for BSHED to
105 review and provide assistance with identifying regulatory or permitting
106 requirements.

107

108 (b) If an individual source (laboratory, fume hood exhaust stack or piece of equipment)
109 will emit of more than 250 pounds of any hazardous air pollutant (identified in 5 CCR
110 1001-5) in a calendar year, an APEN form shall be submitted to CDPHE. The
111 director of the OU responsible for the process generating the waste shall ensure that
112 BSHED is notified.

113

114 (c) Portable generators, whether used by NIST staff or contractors, may be required to be
115 permitted under 5 CCR 1001-5, Part A, II.D, depending upon emissions and operating
116 hours.

117

118 (d) If an emission source emitting more than two tons per year of any criteria pollutant
119 will be constructed, an APEN form shall be submitted to CDPHE.

120
121 (e) In an area designated as a nonattainment area for a specific criteria pollutant, if an
122 emission source emitting more than one ton per year of the pollutant for which the
123 area is classified as a nonattainment area will be constructed, an APEN form shall be
124 completed and submitted to CDPHE.

125
126 NOTE: The Denver Metropolitan Area, including Boulder County, is identified
127 as a severe nonattainment area for ozone resulting in APEN forms having been
128 submitted for all pollutant emitting sources including stationary equipment fueled
129 with diesel or natural gas.

130
131 (2) Particulate Matter from Construction and Demolition

132
133 (a) Land disturbing work exceeding 5 acres shall be required to use available and
134 practical methods, which are technologically feasible and economically reasonable, to
135 control emissions of particulates. See 5 CCR 1001-3,III.D.2.b.

136
137 (b) Construction and/or demolition activities shall be required to obtain a permit for land
138 disturbing activities exceeding 25 acres or 6 months in duration.

139
140 (c) An APEN form and Application for Construction Permit for Land Development form
141 shall be completed and submitted to CDPHE. This requirement is specified in the 5
142 CCR 1001-5, Part B.

143
144 NOTE: The Mile High Flood District Urban Storm Drainage Criteria Manual
145 provides guidance covering the control of particulate emissions.

146
147 (3) Asbestos Containing Material

148 NIST-Boulder shall comply with the requirements of 5 CCR 1001-10, when conducting
149 renovation or demolition activities which may disturb or require abatement of asbestos-
150 containing material.

151
152 (4) Ozone Depleting Substances (e.g., Chlorofluorocarbons)

153 NIST-Boulder shall comply with the requirements in 5 CCR 1001-19 when using
154 regulated ozone depleting substances ([https://www.epa.gov/ozone-layer-
155 protection/ozone-depleting-substances](https://www.epa.gov/ozone-layer-protection/ozone-depleting-substances)), specifically:

156

- 157 (a) The intentional venting of any ozone depleting compound refrigerant shall be
158 prohibited;
159
- 160 (b) Stationary units rated at 100 horsepower or greater by the manufacturer, containing
161 ozone depleting refrigerants shall be registered with CDPHE;
162
- 163 (c) Food refrigeration units containing 300 pounds or more of any ozone depleting
164 compound refrigerant shall be registered with CDPHE and registration shall be
165 updated within 60 days of November 1 of each year;
166
- 167 i. Proof of current registration shall be kept by the division owning a registered
168 unit and shall be made available to CDPHE upon request; and
169
- 170 (d) Refrigerant recovery shall be performed by technicians with the appropriate
171 certification to service the piece of equipment from which refrigerants are to be
172 recovered.
173

174 (5) Open Burning
175

- 176 (a) Open burning shall be prohibited within the City of Boulder per BRC 10-8-2(12).
177
- 178 (b) Non-commercial cooking fires (grills) may be used.
179

180 (6) Report of Excessive Emissions and Deviations
181

- 182 (a) Releases, including air emissions that could endanger human health or the
183 environment, shall be reported to BSHED in accordance with the NIST-Boulder
184 Occupant Emergency Plan (OEP).
185
- 186 i. Odorous emissions not complying with the terms of 5 CCR 1001-4 shall be
187 reported; and
188
- 189 ii. Upon request by CDPHE, NIST shall report (in writing) all deviations from
190 permit conditions within 5 days of receiving the request.
191

192 (7) Testing Requirements
193

- 194 (a) NIST shall conduct testing to determine compliance with the permit upon the request
195 of CDPHE.
196

197 (b) Only emission testing methods approved by CDPHE will be used to demonstrate
198 compliance with air permit requirements.

199
200 (c) Personnel or contractors measuring opacity shall be certified in accordance with
201 Environmental Protection Agency (EPA) Method 9 (40 CFR 60, Appendix A).

202
203 b. Permit Requirements

204
205 (1) Subject Equipment

206 The equipment items which shall be subject to the requirements of this suborder are listed
207 below in Table 6.1. Limits on emissions of NO_x from each source are listed in Appendix
208 B.

209

Table 6.1: Subject Air Emission Sources			
Equipment	AIRS Point	Description	Installation
Boilers #17 and 19	016 and 017	38 MMBtu/hr Superior boilers burning natural gas. Building 42. Owned by Division 194.	2011
Boiler #18	018	38 MMBtu/hr Superior boiler burning natural gas. Building 42. Owned by Division 194.	2012
EMG-025	019	Cummins diesel fueled generator. Maximum horsepower 2220 hp. Northwest corner of Building 81. Owned by Division 194.	2012
EMG-92-001	020	Generac diesel fueled generator. Maximum horsepower 1528 hp. West side of Building 92. Owned by Division 184.	2019
EMG-005	021	Diesel-fueled engine powering an emergency generator. Make: Kohler, Model: 100R0ZJ81, S/N: 338980. Design rated at 134 HP.	1993
EMG-C-019	022	Diesel-fueled engine powering an emergency generator. Make: Cummins, Model: DGHE-5750399, S/N: B060887377. Design rated at 67 HP.	2006

Table 6.1: Subject Air Emission Sources (cont.)

Equipment	AIRS Point	Description	Installation
EMG-026	023	Diesel-fueled engine powering an emergency generator. Make: Cummins, Model: DSHAB-9272815, S/N: L110279537. Design rated at 235 HP.	2012
EMG-03-001	024	Diesel-fueled engine powering an emergency generator. Make: Generac, Model: SD500, S/N: 30011642029. Design rated at 671 HP.	2017
WH-006	025	Natural gas fired boiler. Make: A.O. Smith, Model: T-M50-N, S/N: 39000286. Design rated at 0.38 MMBTU/hr.	
WH-004	026	Natural gas fired boiler. Make: Takagi, Model: T-M50-N, S/N: 39000288. Design rated at 0.38 MMBTU/hr.	
WH-014	027	Natural gas fired boiler. Make: Rheem, Model: 41V50, S/N: 0203V05459. Design rated at 0.04 MMBTU/hr.	2003
WH-016	028	Natural gas fired boiler. Make: Rinnai, Model: C85, S/N: 07-04-000434. Design rated 0.04 MMBTU/hr.	2007
WH-021	029	Natural gas fired boiler. Make: State, Model: SUF-60-120-NE-300, S/N: 1829111215657. Design rated 0.12 MMBTU/hr.	2018
01-EMG-W5-001	030	Diesel emergency generator. Make: Cat, Model: C18 ACERT, S/N: CAT00C18CT3401665. Design rated at 839 HP.	2023
BLR-12	031	Natural gas fired boiler. Make: Lochinvar, Model: FBN0750, S/N: B954458. Design rated at 0.66 MMBTU/hr.	1960
25-BLR-001	032	Natural gas fired boiler. Make: Harsco, Model: N700, S/N: AH13-16-39140. Design rated at 0.7 MMBTU/hr.	2016

Table 6.1: Subject Air Emission Sources (cont.)

Equipment	AIRS Point	Description	Installation
22-BLR-001	033	Natural gas fired boiler. Make: Crest, Model: FBN1501, S/N 1909113872706. Design rated at 1.5 MMBTU/hr.	2019
21-BLR-001	034	Natural gas fired boiler. Make: Aerco, Model: BMK1500, S/N: G-16-0561. Design rated at 1.5 MMBTU/hr.	2016
EMG-C-023	035	Natural gas fired engine powering an emergency generator. Make: Generac, Model: 12521860600, S/N: 2108766. 4 Stroke Turbocharged w/ Lean Burn, designed at 320 hp. Fuel use rate of 798 SCF/Hour at 100% load.	2011
EMG-C-022	036	Natural gas fired engine powering an emergency generator. Make: Generac, Model: 12521860500, S/N: 2108764. 4 Stroke Turbocharged w/ Lean Burn, designed at 320 hp. Fuel use rate of 798 SCF/Hour at 100% load.	2011
EMG-C-021	037	Natural gas fired engine powering an emergency generator. Make: Generac, Model: 12521860500, S/N: 2108765. 4 Stroke Turbocharged w/ Lean Burn, designed at 320 hp. Fuel use rate of 798 SCF/Hour at 100% load.	2011
EMG-020	038	Natural gas fired engine powering an emergency generator. Make: Cummins, Model: GGFD-5861710, S/N: E070065025. 4 Stroke w/ Rich Burn, designed at 74 hp. Fuel use rate of 194 SCF/Hour at 100% load.	2007

Table 6.1: Subject Air Emission Sources (cont.)

Equipment	AIRS Point	Description	Installation
EMG-020	038	Natural gas fired engine powering an emergency generator. Make: Cummins, Model: GGFD-5861710, S/N: E070065025. 4 Stroke w/ Rich Burn, designed at 74 hp. Fuel use rate of 194 SCF/Hour at 100% load.	2007
EMG-014	039	Natural gas fired engine powering an emergency generator. Make: Onan, Model: GGHC-3378971, S/N: I990988707. 4 Stroke Turbocharged w/ Lean Burn, designed at 107 hp. Fuel use rate of 281 SCF/Hour at 100% load.	1999
EMG-013	040	Natural gas fired engine powering an emergency generator. Make: Onan, Model: 45GGFF, S/N: L980832362. 4 Stroke w/ Lean Burn, designed at 60 hp. Fuel use rate 157 SCF/Hour at 100% load.	1998
EMG-003	041	Natural gas fired engine powering an emergency generator. Make: Onan, Model: 11-5GNAB, S/N: I978649545. 4 Stroke w/ Lean Burn, designed at 15 hp. Fuel use rate of 39 SCF/Hour at 100% load.	1997
EMG-001	042	Natural gas fired engine powering an emergency generator. Make: Cummins, Model: 100ENBA, S/N: H93056501. 4 Stroke w/ Rich Burn, designed at 134 hp. Fuel use rate 352 SCF/Hour at 100% load.	2006
EMG-008	043	Natural gas fired engine powering an emergency generator. Make: Onan, Model: 60EN L, S/N: K910433240. 4 Stroke w/ Lean Burn, designed at 81 hp. Fuel use rate 1680 SCF/Hour at 100% load.	1991

Table 6.1: Subject Air Emission Sources (cont.)

Equipment	AIRS Point	Description	Installation
WH-020	044	Natural gas fired boiler. Make: Rheem, Model: XG40T06EC, S/N: 71720560. Design rate at 0.036 MMBTU/hr.	2017
EMG-027	045	Natural gas fired engine powering an emergency generator. Make: Onan, Model: GGHH-1325363, S/N: D130490556. 4 Stroke w/ Lean Burn, designed at 134 hp. Fuel use rate 352 SCF/Hour at 100% load.	2013
EMG-028	046	Natural gas fired engine powering an emergency generator. Make: Generac, Model: GGHH-1325363, S/N: QT02224GNAX. 4 Stroke w/ Lean Burn, designed at 30 hp. Fuel use rate 80 SCF/Hour at 100% load.	2014
01-P-EMG-029	047	Natural gas fired engine powering an emergency generator. Make: Generac, Model: SG100, S/N: 3014977223, 4-Stroke /Rich Burn, 134 hp, 1280 scf/hr	2024
OSY-EMG	TBD	Natural gas fired engine powering an emergency generator. Make: Cummins, Model: C45 N6, S/N: E190562907, 4-Stroke, Lean Burn, 60 HP, 623 scf/hr	2019

210
211
212
213
214
215
216
217
218
219

(2) Equipment Specific Requirements

- (a) Requirements for operation and maintenance of permitted sources may be found in the NIST Boulder Operation and Maintenance (O&M) Plan.
- (b) The Chief of the Emergency Services Office is responsible for ensuring that the emergency generator located to the north of Building 22 (temporarily identified as OSY-EMG) is maintained in accordance with the manufacturer’s instruction and

220 operation hours are reported to the program manager following the end of each
221 month.

222

223 (3) Routine Reporting

224

225 (a) While NIST-Boulder is not required to submit routine reports to CDPHE, NIST shall
226 be required to maintain fuel consumption and emissions data as described below and
227 in Sections 9.e and 9.f. Limits on NO_x emissions for each source are found in
228 Appendix B.

229

230 i. NIST shall maintain fuel consumption and emissions data for the permitted
231 boilers and generators.

232

233 ii. Emissions data shall be calculated for the following criteria pollutants:

234

235 (i) Total Suspended Particulate (TSP) for Boilers 17, 18 and 19;

236

237 (ii) PM₁₀ for Boilers 17, 18 and 19;

238

239 (iii) PM_{2.5} for Boilers 17, 18 and 19;

240

241 (iv) VOCs for Boilers 17, 18 and 19;

242

243 (v) NO_x for all permitted boilers and emergency generators; and

244

245 (vi) Carbon Monoxide for Boilers 17, 18 and 19.

246

247 iii. As allowed under the Synthetic Minor Source Permit, emissions factors
248 provided in the permit shall be used to calculate emissions. If emissions
249 factors for a source were not provided in the permit, the EPA Compilation of
250 Air Pollutant Emissions Factors (AP) 42 emissions factors relevant to the
251 equipment and the efficiency of low-NO_x burners shall be used. The
252 emissions factors identified in the *Notes to Permit Holder* section of the
253 permit shall be used.

254

255 iv. On a monthly basis, emissions shall be calculated using the fuel consumption
256 data for each source during the previous month and the emissions factors
257 identified above.

258

259 v. Emissions shall be tracked in a spreadsheet or database as a 12-month rolling
260 total.

261
262 (b) Boilers and generators shall be operated per the specifications shown in Table 6.2.

263
264 i. Equipment subject to this Suborder shall be maintained in a manner that
265 ensures compliance with performance requirements established in the permit.

266
267 ii. Procedures for operation and maintenance of boilers, emergency generators
268 and natural gas-fueled water heaters shall be documented in an operations and
269 maintenance plan.

270
271 iii. Operation and maintenance requirements are identified in the NIST Boulder
272 Operations and Maintenance Plan.

273
274 NOTE: Responsibilities for maintenance are established in Section 9 below.

275

Table 6.2: Key Operating Parameters			
Equipment	Key Parameter	Critical Operating Range	Monitoring Procedure and Frequency
Natural Gas Boilers, Generators and Water Heaters	Opacity/Visible Emissions	≤20% opacity when operating (EPA Method 9) ≤30% opacity for more than 6 minutes during startup	Opacity Testing at Startup or Issuance of Permit. Upon request by CDPHE.
	Odor	Detectable odor	Upon request by CDPHE.
Diesel Emergency Generators	Opacity/Visible Emissions	≤20% opacity when operating ≤30% opacity for more than 6 minutes during startup	Opacity Testing at Startup or Issuance of Permit. Upon request by CDPHE.
	Odor	Detectable odor	Upon request by CDPHE.
	Fuel	Maximum 15 ppm sulfur and Minimum cetane rating 40 or Maximum aromatic compounds 35%	Maintain specifications sheet from fuel vendor

276
277
278
279
280
281
282
283
284
285

c. Training

- (1) Training shall be provided, documented, and recorded in accordance with the requirements of the NIST S 7101.23.
- (2) Parties with responsibilities for the construction or modification of air pollutant emissions sources shall complete:
 - (a) [NIST S 7301.11: Environmental Requirements for Construction Contracts - Boulder.](#)

286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325

(3) Employees and associates except those identified in Section 6.c(2) shall complete the Accidental Hazardous Material Release Training appropriate to their duties, either:

(a) [NIST S 7301.07: Accidental Hazardous Material Release Training for Users](#); or

(b) [NIST S 7301.07: Accidental Hazardous Material Release Training for Non-Users](#)

d. Evaluation of Compliance

(1) BSHED shall conduct a compliance evaluation of the regulatory requirements of this program on at least an annual basis.

(2) Results of compliance evaluations shall be documented and records maintained as environmental management system (EMS) records per Section 6.e.

(3) Significant findings from compliance evaluations shall be addressed using the NIST S 7301.01 requirements for Non-Conformances, Corrective and Preventive Action.

e. Records

(1) NIST shall maintain records as necessary to demonstrate compliance with the permit and other general emission related regulations.

(2) Appendix B (EMS Procedure 15.0) of NIST S 7301.01 shall be used to ensure proper identification, storage, protection, retrieval, retention, and disposal of records.

(a) Records needed to demonstrate compliance with permit requirements shall be maintained by the NIST Facilities Maintenance Division-Boulder (FMD-B). These include:

i. Maintenance logs of permitted boilers indicating records of:

(i) Startups;

(ii) Shutdowns; and

(iii) Malfunctions.

ii. Operations records indicating:

- 326
327 (i) Water consumption by boilers (gallons per day, gpd);
328
329 (ii) Fuel consumption (standard cubic feet/day, scf/day) by boilers; and
330
331 (iii) Operating hours (emergency generators and water heaters).

332
333 (b) BSHED shall maintain the following records:

- 334 i. Permit Applications, including APEN forms;
335
336 ii. Permits;
337
338 iii. Regulatory Correspondence;
339
340 iv. Regulatory Inspection Reports;
341
342 v. Audit Reports;
343
344 vi. Fuel Use/Emissions Calculations;
345
346 vii. Monitoring Reports, if required by CDPHE; and
347
348 viii. Emergency Notification/Release Reports.
349

350
351 (c) All records required by this Suborder will be maintained for a period of five (5) years.
352
353
354

355 7. DEFINITIONS

356 Definitions common to all NIST EMS suborders can be found in Section 6 of NIST O
357 7301.00. Definitions specific to this suborder:

- 358
359 a. Construction Permit – Permit issued by the Colorado Department of Public Health and
360 Environment authorizing the construction of sources emitting criteria pollutants.
361
362 b. Criteria Pollutant – Pollutants for which EPA has established national ambient air quality
363 standards, including carbon monoxide, nitrogen dioxide, sulfur dioxide, total suspended
364 particulate matter, PM10, PM2.5, ozone, volatile organic compounds and lead. In addition,
365 an APEN must be submitted if a source will emit greater than two tons per year of the

366 following: nitrogen oxides, fluorides, sulfuric acid mist, hydrogen sulfide, total reduced
367 sulfur, reduced sulfur compounds, municipal waste combustor metals and municipal waste
368 combustor acid gases.

369

370 c. Open Burning – The burning of material where combustion products are emitted directly into
371 the ambient air without first passing through a chimney or stack.

372

373 d. Ozone-Depleting Substances – Any chemical listed as a Class I or Class II substance in
374 Section 602 of the Clean Air Act. These are substances that deplete the ozone layer and are
375 widely used in refrigerators and air conditioning equipment.

376

377 e. Particulate Matter – Pollutant that includes dust, soot, and other heterogeneous small, solid
378 materials released into and transported by the air, including particulate matter 2.5µm or less
379 than in diameter (PM_{2.5}), particulate matter 10 µm or less in diameter (PM₁₀) and all
380 particulate matter suspended in air (total suspended particulate or TSP).

381

382 f. Part 70, Title V Air Permit – A federally enforceable operating permit issued under 40 CFR
383 Part 70 which regulates the emissions of air pollutants.

384

385 g. Synthetic Minor Source – A source that has the potential to emit regulated pollutants in
386 amounts that are at or above the thresholds for major sources but has taken restrictions so that
387 its potential to release is less than the threshold for being regulated as a major source.

388

389

390 8. ACRONYMS

391 Acronyms common to all NIST EMS suborders can be found in Section 7 of NIST O 7301.00.

392 The acronyms specific to this suborder are as follows:

393

394 a. AIRS – Colorado Aerometric Information Retrieval System

395 b. AP 42 – EPA Compilation of Emissions Factors

396

397 c. APCD – Air Pollution Control Division of the Colorado Department of Public Health and
398 Environment

399

400 d. APEN – Air Pollutant Emission Notice form

401

402 e. BSHED – Boulder Safety, Health and Environment Division (153)

403

404 f. CDPHE – Colorado Department of Public Health and Environment

405

- 406 g. CUP – Boulder Central Utilities Plant
407
408 h. DCD-B – Design and Construction Division – Boulder (196)
409
410 i. EMS – Environmental Management System
411
412 j. EPA – Environmental Protection Agency
413
414 k. FMD-B – Facilities Maintenance Division – Boulder (194)
415
416 l. HAP – Hazardous Air Pollutant
417
418 m. MMBTU – Million British Thermal Units
419
420 n. MMscf – Million standard cubic feet
421
422 o. NO_x – Nitrogen Oxides
423
424 p. ODS – Ozone Depleting Substance
425
426 q. OEP – Occupant Emergency Plan
427
428 r. OFPM – Office of Facilities and Property Management
429
430 s. OISM – Office of Information Systems Management
431
432 t. OSHE – Office of Safety, Health, and Environment
433
434 u. PM – Particulate Matter
435
436 v. PM_{2.5} – Particulate Matter less than 2.5 μ m in diameter
437
438 w. PM₁₀ – Particulate Matter less than 10 μ m in diameter
439
440 x. SCC – Source Compilation Code
441
442 y. scf – Standard cubic feet
443
444 z. SO_x – Sulfur Oxides
445

446 aa. TBD – To be determined

447

448 bb. TPY – Tons per year

449

450 cc. VOC – Volatile Organic Compounds

451

452

453 9. RESPONSIBILITIES

454 Roles and responsibilities common to all NIST Environmental Suborders can be found in
455 Section 8 of NIST O 7301.00. The roles and responsibilities specific to this suborder are as
456 follows:

457

458 a. Chief Safety Officer is responsible for overseeing NIST's efforts in complying with the
459 requirements identified in this suborder.

460

461 b. OU Directors are responsible for:

462

463 (1) Establishing and implementing policies and procedures, as needed, for the requirements
464 of this suborder to be met;

465

466 (2) Ensuring subordinate managers have the authority, resources, and training needed to
467 implement OU-established policies and procedures; and

468

469 (3) Using OU funds to pay any civil penalties identified in regulatory inspections and
470 resulting from regulatory violations related to equipment owned by their respective OUs.

471

472 c. Division Chiefs are responsible for:

473

474 (1) Implementing this suborder as it applies to activities involving their personnel and space
475 in accordance with any applicable OU-established policies and procedures;

476 (2) Ensuring air emissions sources owned by the division are operated and maintained in
477 compliance with the permit and applicable regulations, including ensuring that fuel use
478 records, operating hours or other data are provided to BSHED. This may be
479 accomplished through a work order under which OFPM maintains the source;

480

481 (3) Ensuring sources owned by the division are identified with a tag or sign identifying the
482 property identification number and AIRS point number.

483

484 (4) Ensuring regulatory inspectors are provided access to areas under their supervision;

485

- 486 (5) Ensuring corrective actions are completed in the timeframe specified by the regulatory
487 agency;
488
- 489 (6) Ensuring CDPHE or EPA inspectors are able to obtain access to areas under that
490 manager's supervision; and
491
- 492 (7) Ensuring deficiencies or violations resulting from regulatory inspections of areas
493 operated by that OU are addressed in the timeframe required by the regulatory agency.
494
- 495 d. The NIST Boulder Air Emissions Program Manager is responsible for:
496
- 497 (1) Acting as the NIST point of contact with regulatory agencies for air pollution issues,
498 including coordinating inspections by regulatory agencies;
499
- 500 (2) Determining whether a proposed source is subject to APEN or permitting requirements.
501 CDPHE provides a checklist for evaluation;
502
- 503 (3) Submitting APEN, Notices-of-Startup and Self Certification forms to CPDHE in a
504 timely manner;
505
- 506 (4) Supporting OFPM regarding finding contractors to perform compliance testing when
507 required;
508
- 509 (5) Supporting OFPM by advising when emissions are at risk of exceeding permitted
510 levels;
511
- 512 (6) Maintaining a spreadsheet to calculate emissions from sources listed in Table 6.1;
513
- 514 NOTE: Fuel use data is provided by OFPM, OISM (184), and the Time and
515 Frequency Division (688) via work order through OFPM.
- 516 (7) Performing an internal compliance evaluation once per calendar year at a minimum to
517 verify ongoing compliance with the permit;
518
- 519 (8) Reporting to the CDPHE as specified in Section 6.b;
520
- 521 (9) Communicating the regulatory requirements to affected personnel;
522
- 523 (10) Maintaining this Suborder and keeping it up to date; and
524
- 525 (11) Maintaining general records identified in Section 6.n.

526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565

- e. The NIST Chief Facilities Management Office is responsible for:
- (1) Ensuring information required for completion of APENs, Notices-of-Startup and Self Certification forms is provided to BSHED;
 - (2) Ensuring compliance testing required under the permit is performed in compliance with permit requirements, within the timeframe specified in the permit following installation of a new source;
 - (3) Ensuring the AIRS point number is affixed to a source within the timeframe specified in the permit following installation of the source. Tags similar to NIST property identification tags are acceptable;
 - (4) Ensuring sources listed in the permit and this suborder are operated in a manner that does not exceed the permitted fuel use or emissions limits;
 - (5) Ensuring sources listed in the permit and this suborder are operated in a manner that does not exceed the following limits: 20% opacity when in operation and opacity not exceeding 30% for more than 6 minutes out of an hour;
 - (6) Ensuring sources listed in the permit and this suborder are operated in a manner that does not exceed the odor control requirements of Air Quality Control Commission Regulation Number 2 (5 CCR 1001-4);
 - (7) Ensuring contracts for operation and maintenance of Boilers 17 – 19 identify the applicable requirements of this suborder and the permit;
 - (8) Ensuring records of fuel usage are provided to BSHED following the end of each month;
 - (9) Ensuring emissions from emergency generators do not exceed New Source Performance Standards specified in the permit;
 - (10) Ensuring fuel specifications for fuel used in diesel emergency generators are maintained on site and that fuel contains no more than 15 ppm sulfur (by volume), has a minimal cetane rating of 40 and is no more than 35% aromatic compounds (by volume);
 - (11) Ensuring petroleum storage tanks associated with emergency generators are inspected in accordance with the NIST Boulder Spill Prevention, Control and Countermeasures (SPCC) Plan;

- 566
567 (12) Ensuring land disturbing activities exceeding one acre (managed by FMD-B personnel)
568 control particulate emissions if less than six months in duration;
569
570 (13) Ensuring land disturbing activities exceeding five acres or six months in duration
571 (managed by FMD-B personnel), not meeting the requirements for an exception under 5
572 CCR 1001-5,A.II.D.1.j, are covered under an APEN submitted to CDPHE;
573
574 (14) Obtaining and maintaining training for personnel as identified in the NIST Boulder
575 (Synthetic Minor) Construction Permit 09BO0159 and Section 6.l; and
576
577 (15) Immediately reporting any nonconformance, excursion or release of hazardous material
578 to BSHED.
579
580 (16) Ensuring BSHED, by way of a completed Planning Checklist portion of the
581 Environmental Checklist being submitted to the program manager, is notified of planned
582 installation of boilers, emergency generators or other sources of air pollutants;
583
584 (17) Ensuring information required for completion and submission of APEN forms is
585 provided to BSHED for the following equipment or activities;
586
587 (a) Construction/installation of boilers and generators;
588
589 (b) Land disturbing activities; and
590
591 (c) Portable emissions sources.
592
593 (18) Ensuring sources of air pollutants are constructed or installed in accordance with the
594 timeline specified in the permit (within 18 months of the permit being modified and re-
595 issued) or that BSHED is informed of delays in time to request extension of the
596 construction period;
597
598 (19) Ensuring boilers, generators and other air pollutant sources are transferred to FMD-B
599 after construction or installation. This includes supplying all drawings and specifications
600 such as operations and maintenance manuals;
601
602 (20) Ensuring land disturbing activities exceeding one acre (managed by DCD-B personnel)
603 control particulate emissions if less than six months in duration and not subject to
604 requirements to submit an APEN to CDPHE; and
605

606 (21) Ensuring all renovation or demolition activities conducted at NIST Boulder involving
607 asbestos-containing materials are conducted in accordance with all applicable Federal
608 and State regulations

609

610 f. NIST Employees and Associates are responsible for:

611

612 (1) Reporting to NIST BSHED any activity that may release significant airborne pollutants
613 into the environment, see Section 6.a(1)(b); and

614

615 (2) Reporting any out of the ordinary air emissions to the emergency number (x7777).

616

617

618 **10. AUTHORITIES**

619 There are no authorities specific to this suborder alone. For authorities applicable to all NIST
620 Environmental Suborders, see section 9 of NIST O 7301.00.

621

622

623 **11. DIRECTIVE OWNER**

624 Chief Safety Officer

625

626

627 **12. APPENDICES**

628 A. Revision History

629

630 B. Regulatory Requirements for Subject Equipment

631

632

633
634
635

Appendix A. Revision History

Version	Document Approval	Effective Date	Description of Change
1	01/12/2021	01/12/2021	None – initial document.
2	07/27/2022	07/27/2022	OFPM responsibilities consolidated under CFMO, grammatical corrections, added two conditionally APEN-exempt sources and operating hour limits
3	11/19/2025	11/19/2025	Updated to reflect new permit requirements

636
637
638

Appendix B: Regulatory Requirements for Subject Equipment

Air Pollutant Sources Operations Limits						
Equipment	AIRS Point	Fuel	NO_x (tpy)	CO (tpy)	Test & Maintenance Hours (per year)	Fuel Consumption Limits (MMscf)
BLR-017	016	NG	3.75	6.3		150
BLR-019	017	NG	3.75	6.3		150
BLR-019	018	NG	3.75	6.3		150
EMG-025	019	Diesel	3.84		100	
EMG-92-001	020	Diesel	2.64		100	
EMG-005	021	Diesel	0.30		100	
EMG-C-019	022	Diesel	0.15		100	
EMG-026	023	Diesel	0.52		100	
EMG-03-001	024	Diesel	1.16		100	
WH-006	025	NG	0.02			0.22
WH-004	026	NG	0.02			0.22
WH-014	027	NG	0.01			0.024
WH-016	028	NG	0.01			0.024
WH-021	029	NG	0.01			0.071
01-EMG-W5-001	030	Diesel	1.38		100	
BLR-12	031	NG	0.29			2.8
25-BLR-001	032	NG	0.30			3.5
22-BLR-001	033	NG	0.65			5
21-BLR-001	034	NG	0.35			7
EMG-C-023	035	NG	0.01		100	0.144
EMG-C-022	036	NG	0.01		100	0.144
EMG-C-021	037	NG	0.01		100	0.144
EMG-020	038	NG	0.03		100	0.023
EMG-014	039	NG	0.02		100	0.034
EMG-013	040	NG	0.01		100	0.019
EMG-003	041	NG	0.01		100	0.0047
EMG-001	042	NG	0.05		100	0.042
EMG-008	043	NG	0.05		100	0.036
WH-020	044	NG	0.01			0.021
EMG-027	045	NG	0.09		100	0.063
EMG-028	046	NG	0.02		100	0.0144
01-P-EMG-001	TBD	NG	0.01			0.23
OSY-EMG	TBD	NG	0.005			0.112