

HALON ALTERNATIVES: RECENT TECHNICAL PROGRESS

Mark L. Robin
Great Lakes Chemical Corporation
Fluorine Chemicals Department
P.O. Box 2200
West Lafayette, IN 47906
(317-497-6360 FAX 317-497-6234)

ABSTRACT

Recent progress in the development of Halon alternatives at Great Lakes Chemical Corporation is presented. Large scale fire test results are presented for the extinguishment of n-heptane pool fires by **FM-100** (bromodifluoromethane), **FM-200** (1,1,1,2,3,3,3-heptafluoropropane) and **HFC-23** (trifluoromethane). Critical properties, vapor pressures, and liquid and vapor molar volumes have been measured for **FM-100** and **FM-200**, and the experimental data fit to the Carnahan-Starling-DeSantis (CSD) equation of state. Tables of saturation and superheated vapor properties are generated for **FM-100** and **FM-200**, and pressure-enthalpy diagrams constructed for both agents. A complete set of thermodynamic properties is thus made available for use in the design of fire suppression systems employing these new agents.

INTRODUCTION

Regulations on the production and use of the Halon fire suppression agents Halon 1301 (bromotrifluoromethane) and Halon 1211 (bromochlorodifluoromethane) have resulted in intensive efforts in both the industrial and academic sectors to find environmentally acceptable replacements for these agents.

FM-100 (bromodifluoromethane) and **FM-200** (1,1,1,2,3,3,3-heptafluoropropane) are environmentally superior fire suppression agents developed by Great Lakes Chemical Corporation [1,2]. **FM-200** has an ozone depletion potential (ODP) of zero, and hence presents no threat to the stratospheric ozone layer. **FM-100** is also an environmentally superior fire suppression agent, providing a greater than 90% reduction in ODP compared to Halon 1301. A selection of properties of **FM-100** and **FM-200** of interest in fire suppression applications are summarized in Table 1.

TABLE 1: PROPERTIES OF FIRE SUPPRESSION AGENTS

	FM-100	FM-200	HALON 1301	HALON 1211
Chemical Formula	CF ₂ HBr	CF ₃ CHFCF ₃	CF ₃ Br	CF ₂ BrCl
Molecular weight	130.92	170.03	148.91	165.37
Boiling point	4.14 °F -15.48 °C	2.55 °F -16.36 °C	-71.95 °F -57.75 °C	24.80 °F -4.00 °C
Melting point	-229 °F -145 °C	-204 °F -131 °C	-270 °F -168 °C	-256.00 °F -160.00 °C
critical Temperature	281.89 °F 138.83 °C	215.02 °F 101.68 °C	152.60 °F 67.00 °C	308.84 °F 153.80 °C
critical Pressure	744 psia 5.132 MPa	422 psia 2.912 MPa	575 psia 3.964 MPa	595 psia 4.102 MPa
critical Density	49.0 lb/ft ³ 0.784 kg/L	38.7 lb/ft ³ 0.621 kg/L	46.5 lb/ft ³ 0.745 kg/L	44.4 lb/ft ³ 0.713 kg/L
Extinguishing Concentration, cupburner, % v/v (n-heptane)	3.9	6.0	3.5	3.7
Inerting Conc %v/v (Stoichiometric)				
Methane	6	8	4	-
Propane (Reference 3)	8	12	8	
LC ₅₀ (4 hour)	108,000	>800,000	800,000	131,000

Requirements for a viable Halon alternative include **good** fire suppression characteristics, low toxicity, minimal formation of decomposition products during extinguishment, and compatibility with materials of construction. In addition, to properly evaluate the performance of a Halon alternative in a fire suppression system and to enable the design of a suppression system for a given application, a complete set of thermodynamic properties is required. **This study reports** on the extinguishing efficiency of FM-100, FM-200 and HFC-23, and the decomposition products produced upon extinguishment of n-heptane pool **fires** by these agents in a 1440 cubic foot test facility. Also *reported* is the determination of a complete set of thermodynamic properties for the agents FM-100 and FM-200 by the fitting of experimentally measured critical properties, vapor pressure, and liquid and vapor volumes to the **Carnahan-Starling-DeSantis** equation of state.

LARGE *SCALE* FIRE TESTING

It is well known that the presently employed Halon fire extinguishing agents produce both hydrogen fluoride (HF) and hydrogen bromide (HBr) in the combustion environment [4-9]. Due to the toxic and corrosive nature of these halogen acids, it is important to ascertain the concentrations of these products formed upon extinguishment of a fire with a particular agent.

Agent efficiencies and decomposition products were determined employing the test facility shown schematically in Figures 1 and 2. The facility consists of a plywood structure of internal dimensions 12 ft (length) x 10 ft (width) x 12 ft (height), corresponding to an internal volume of 1440 cubic feet. The facility is constructed from 2x4 lumber and 3/4" plywood, and the inside surfaces are painted with an oil-based primer (KILZ). A 3 ft x 3 ft hinged "trap door" was located on the ceiling to allow venting in the event of overpressurization.


The agent delivery system consisted of 1 1/2" carbon steel pipe, a single lateral dispersion type nozzle (FIKE 80-029) located in the center of the ceiling, and a FIKE Halon 1301 cylinder fitted with a 1" pyrotechnic assembly or a manually activated ball valve. The delivery system was fitted at the nozzle with an Omega series PX302-500GV pressure transducer to allow determination of the agent discharge time. Fuel and flame temperatures were monitored with Type K exposed junction thermocouples with Inconel sheaths. Data acquisition was accomplished with a Rustrak Ranger datalogger (Gulton-Rustrak) with a Pronto Release 3 software package.

A metal fire pan (3.5" x 3.5" x 4" deep or 11.5" x 11.5" x 4" deep) was located in the center of the test facility and filled with two inches of water, followed by one inch of commercial grade n-heptane. The fuel was ignited and allowed a 30 second preburn period with both doors open. The doors were then closed and the agent discharged. Extinguishment times were determined by visual observation employing a stopwatch, and discharge times were determined from the variation of the nozzle pressure with time.

An all plastic collection system located inside the test facility was employed for the determination of halogen acid decomposition products. This system consists of a 250 cc polypropylene gas washing bottle equipped with a 70 micron porosity polyethylene disk. In the case of Halon 1301 and FM-100, the gas washing bottle was filled with 100 cc of deionized water and the acid halides determined by ion chromatography (IC) on a Dionex Ionpack AS4A column with 2 mM sodium carbonate/2 mM sodium bicarbonate eluent. For FM-200 and HFC-23, HF was determined via IC as described above, and also by ion selective electrode (ISE), employing


FIRE TEST FACILITY

FIGURE 1.



FIRE TEST FACILITY

FIGURE 2.



110cc of an ionic strength adjusting solution (TISAB IV, Orion) in place of the deionized water. Either method produced similar results for the concentrations of HF. Halogen acid samples were collected beginning 30 seconds after agent discharge by pulling enclosure air through the gas washing bottles with calibrated vacuum pumps for a total of 10 minutes. Based upon the amount of halogen acids collected in the gas washing bottle, the concentration of halogen acids produced in the test facility volume can be calculated. Additional details of the sampling procedure have been presented elsewhere [10].

The experimentally measured concentrations of hydrogen fluoride and hydrogen bromide produced from Halon 1301, FM-100, FM-200 and HFC-23 are summarized in Tables 2 and 3 for small (0.06 ft² fuel surface area per 1000 ft³ enclosure volume) and large (0.60 ft² fuel surface area per 1000 ft³ enclosure volume) n-heptane pool fires, respectively. For each agent, at least five tests were conducted for each fire size.

TABLE 2. COMPARISON OF FIRE SUPPRESSION AGENTS
Small fires (0.06 ft²/1000 ft³)

Agent	Concentration % v/v	Discharge Time, s	HF (ppm)	HBr (ppm)
H-1301	5	4.5	3.9 +/- 1.2	2.6 +/- 1.3
FM- 100	5	6.0	3.9 +/- 1.0	14 +/- 10
FM-200	8	6.5	25 +/- 10	-

1.5" pipe, 1.5" nozzle (FIKE 80-029)

TABLE 3. COMPARISON OF FIRE SUPPRESSION AGENTS
Large fires (0.60 ft²/1000 ft³)

Agent	Concentration % v/v	Discharge Time, s	HF (ppm)	HBr (ppm)
H-1301	5	4.5	78 +/- 48	25 +/- 6
FM- 100	5	6.0	53 +/- 23	32 +/- 9
FM-200	10	6.5	503 +/- 123	-
HFC-23	16	8.0	1259 +/- 159	-
HFC-23	18	9.0	805 +/- 209	-

1.5" pipe, 1.5" nozzle (FIKE 80-029)

For the results presented in Tables 2 and 3 the delivery system was constructed of 1 1/2" carbon steel with a 1 1/2" standard nozzle (FIKE 80-029). Since no changes were made to the system (i.e., no attempts were made to optimize the system for a particular agent), the tests serve to evaluate the alternatives when employed as "drop-in" agents. The design concentrations given in the tables are the lowest concentrations of agent which result in extinguishment of the fire in a time period less than or equal to the agent discharge time.

For the **small fires**, FM-100 at **5 %** by volume produced similar levels of HF and HBr compared to those produced from Halon 1301 at **5 %** by volume. The halodifluoromethanes are known to readily decompose at elevated temperatures via elimination of HX [11], and this may explain the somewhat increased levels of HBr observed with FM-100 compared to Halon 1301. For the large **fires**, FM-100 at **5 %** by volume again produced similar levels of HF and HBr compared to those produced from Halon 1301 at **5 %** by volume. Extinguishment of both small and large fires with FM-100 was rapid and clean (no residues). The results demonstrate that on a weight basis FM-100 is equal in efficiency to Halon 1301. Replacement of Halon 1301 with FM-100 provides equal **fire** extinguishing efficiency and cleanliness, with a significant decrease in ozone-depleting properties.

For the small fires, FM-200 at **8 %** by volume produced rapid and clean extinguishment with the production of HF levels in the range of 15 to 35 ppm, approximately six times the amount produced by Halon 1301 at **5 %** by volume in the same fire scenario. **For** the large fires, **8 %** by volume FM-200 was sufficient to rapidly extinguish the fire, but the levels of HF produced were excessive (**> 1000** ppm). At a concentration of **10 %** by volume, FM-200 provided rapid and clean extinguishment **of** the large fires, and produced HF levels in the range of 380 to 626 ppm; these HF levels are again approximately six times those produced by Halon 1301 at **5 %** by volume in **an** identical fire scenario. At these HF levels no etching of the observation windows was observed. Electronic circuits exposed to the fire environment were operational following exposure, and showed no signs of residues or other adverse affects, other than a slight tarnishing of solder joints.

At a concentration of **16 %** by volume, HFC-23 was able to extinguish the large fires, but HF levels were in excess of **1000** ppm. At a concentration of **18 %** by volume, HFC-23 provided rapid and clean extinguishment, producing HF levels ranging from 596 to **1014** ppm. **These** HF levels **are** approximately ten times those produced by Halon 1301 at **5 %** by volume in an identical **fire** scenario. It should be noted that at these high concentrations, overpressurization of the test

facility can become a problem if the leakage rate of the facility is not great enough to prevent excessive pressure buildup.

It is of interest to compare the above results with literature citations concerning the toxicology of HF. Purser [12], in the SFPE Handbook of Fire Protection, cites a 30 minute mammalian LC₅₀ for HF of 900 - 3600 ppm and Taylor [13], in the NFPA Handbook of Fire Protection, indicates a 10 minute ALC₅₀ for HF of 2500 ppm. It is noteworthy that the levels of HF observed during extinguishment with FM-100 and FM-200 are below these LC₅₀ values.

THERMODYNAMIC PROPERTIES

Measurement of the properties of FM-100 and FM-200 were performed under the direction of Professor W. Alexander Van Hook of the Department of Chemistry, University of Tennessee. Sample purities for both FM-100 and FM-200 were in excess of 0.9995 mole fraction, determined by gas chromatographic analysis. Complete details of the determination of the PVT properties of FM-100 and FM-200 have been described elsewhere [14], as have details of the PVT apparatus and techniques employed in these studies [15]. Critical temperatures were determined by visually noting the loss of meniscus in sealed capillaries. Critical pressures were obtained by extrapolating the vapor pressure expression to T_c, and critical densities were determined from the law of rectilinear diameters. Table 1 summarizes the critical properties and other properties of FM-100 and FM-200, as well as properties for Halon 1301 [16] and Halon 1211 [17] from the literature.

The experimental vapor pressure data for FM-100 and FM-200 were smoothed by least-squares fitting to the vapor pressure equation shown in Table 4, and experimental liquid molar volumes were smoothed by least-squares fitting to the expression shown in Table 5. Vapor molar volumes were calculated from the experimental critical properties employing the generalized virial-coefficient correlation of Pitzer and Curl [18].

TABLE 4. VAPOR PRESSURE CORRELATION

$$\ln P = A_0 + \frac{A_1}{T} + A_2 T + A_3 \ln T$$

$$P = \text{Pa}; T = \text{Kelvin}$$

	A ₀	A ₁	A ₂	A ₃
FM-100	110.8260	-5264.060	2.21845E-2	-15.23629
FM-200	124.7789	-5672.184	2.605601E-2	-17.63847

TABLE 5. LIQUID MOLAR VOLUME CORRELATION

$$\ln V_0 = E_0 + E_1 T + E_2 T^2 + E_3 T^3$$

$$V_0 = \text{m}^3/\text{mole}; T = \text{Kelvin}$$

	E ₀	E ₁	E ₂	E ₃
FM-100	-15.4705	5.4755E-2	-1.7354E-4	1.9033E-7
FM-200	-20.5100	0.11550	-3.9393E-4	4.5585E-7

The experimental data was fit to the Carnahan-Starling-DeSantis (CSD) equation of state and the fitted parameters are detailed in Table 6. Also included in Table 6 are the CSD coefficients for Halon 1301 and Halon 1211, determined by fitting the CSD equation to literature values for the properties of the agents [16,17]. The CSD equation of state has been shown to accurately describe the properties of fluorinated molecules such as the commonly employed refrigerants (R11, R12, R13, R22, R23, R113, R114) as well as the properties of the more recently developed CFC replacements, including R123, R134a, R152a and R125 [19-21]. The CSD equation of state is applicable to both the liquid and vapor phases, its principle limitation being its failure to accurately describe properties in the critical region [19]. However, since in the vast majority of practical applications operation in the critical region is avoided, this limitation does not pose a problem.

TABLE 6. CARNAHAN-STARLING-DESANTIS COEFFICIENTS

$$\frac{pV}{RT} = \frac{1 + (b/4V) + (b/4V)^2 - (b/4V)^3}{[1 - (b/4V)]^3} - \frac{a}{RT(V+b)}$$

$$a = a_0 \exp(a_1 T + a_2 T^2)$$

$$b = b_0 + b_1 T + b_2 T^2$$

$$c_p = c_0 + c_1 T + c_2 T^2$$

	FM-100	FM-200	H-1301	H-1211
a ₀	1772.01	5124.05	2503.14	4749.90
a ₁	0.127422E-2	-0.209572E-2	-0.215184E-2	-0.333938E-2
a ₂	-0.685486E-5	-0.370377E-5	-0.273976E-5	0.810944E-6
b ₀	0.656975E-1	0.194429	0.142871	0.175794
b ₁	0.257243E-3	-0.888528E-4	-0.205155E-3	-0.255102E-3
b ₂	-0.671013E-6	-0.462247E-6	-0.353784E-7	0.841644E-7
c ₀	26.5716	-17.0985	22.5312	22.0184
c ₁	0.125052	0.575753	0.195767	0.235464
c ₂	-0.569902E-4	-0.369941E-3	-0.135512E-3	-0.198691E-3

Tables 7 and 8 compare the experimentally observed values for the vapor pressure and liquid densities of FM-200 with those calculated from the CSD equation of state, and it is seen that the agreement between the calculated and experimental values is excellent.

The temperature dependence of the ideal **gas** heat capacity is **required** in addition to the PVT equation of state to completely express the thermodynamic properties of a fluid. The ideal gas heat capacity for FM-100, derived from spectroscopic data [22] was fit to a simple polynomial as shown in Table 6. Due to the **increased** complexity of FM-200, derivation of the ideal gas heat capacity from IR or Raman spectra was not possible. In this case the temperature dependence of the ideal gas heat capacity **was** estimated by the method of Rihani and Doraiswamy [23].

TABLE 7. FM-200 VAPOR PRESSURE: EXPERIMENTAL VS. CSD EQUATION OF STATE

T(K)	P (kPa) observed	P [*] (kPa) calculated	Difference %
237.65	40.86	40.67	0.47
243.60	55.12	54.98	0.26
248.16	68.61	68.47	0.20
252.39	83.25	83.23	0.02
260.92	120.44	120.60	-0.13
268.31	161.53	162.63	-0.68
275.69	216.08	215.19	0.41
283.20	281.68	281.23	0.16
290.57	359.18	360.12	-0.26
298.22	458.72	458.69	0.01
305.58	576.29	571.46	0.84
313.08	707.05	706.45	0.08
320.66	864.81	865.48	-0.08
328.60	1057.90	1058.64	-0.07
335.24	1242.42	1242.69	-0.02
343.45	1503.39	1500.64	0.18

TABLE 8. FM-200 LIQUID DENSITY: EXPERIMENTAL VS CSD EQUATION OF STATE

T(K)	Density (kg/m ³) observed	Density (kg/m ³) calculated	Difference %
257.55	1521.6	1526.4	-0.32
273.15	1488.2	1475.8	0.83
273.16	1489.0	1475.8	0.89
303.07	1372.1	1370.3	0.13
303.15	1367.0	1370.0	-0.22
322.93	1281.4	1290.4	-0.70
343.38	1188.7	1194.3	-0.47

Employing the equation of state and ideal gas heat capacity constants shown in Table 6, tables of the thermodynamic properties of the agents were generated. **As** an example, saturation and superheated vapor properties for **FM-200** are shown in Tables 9 and 10, respectively. Saturation and superheated vapor properties are conveniently summarized in a pressure-enthalpy (Mollier) diagram, and a series of computer routines were devised which allowed calculation of the pressure-enthalpy diagram. The pressure-enthalpy diagram for **FM-200** is reproduced in Figure 3. The availability of reliable superheated vapor properties also allows the construction of total **flooding** quantity tables, and the total flooding quantity table for **FM-200** is shown in Table 11.

CONCLUSIONS

For both small and large fires, the extinguishing efficiency of **FM-100** on a weight basis was observed to be equal to that of Halon 1301 for similar fire scenarios. **FM-100** provided rapid and clean extinguishment, and produced **HF** and **HBr** at levels similar to that produced by Halon 1301.

Small fires were rapidly and cleanly extinguished by **8%** by volume **FM-200** and the **HF** produced was approximately six times that produced by Halon 1301 at **5%** by volume. The low levels of **HF** produced from **FM-200** (16-35 ppm) are likely insignificant when consideration is given to the potential hazards presented by the fire itself. These results suggest that if fire detection systems of sufficient sensitivity are employed to allow detection and agent release in the early stages when the fire size is minimal, **FM-200** can serve as a viable, environmentally acceptable substitute for Halon 1301 in total flooding applications. Large fires were rapidly and cleanly extinguished by **FM-200** at a concentration of **10%** by volume and produced **HF** in levels ranging from 380 to 626 ppm. These levels compare to cited values for the 30 minute mammalian **LC₅₀** for **HF** of 900 - 3600 ppm, and a 10 minute **ALC₅₀** of 2500 ppm.

At concentrations of 16 to 18% by volume **HFC-23** provided rapid and clean extinguishment of large fires. However, **HF** levels produced were approximately ten times those produced by Halon 1301 in a similar fire scenario, and overpressurization of the test enclosure at these high concentrations also occurred.

TABLE 9. SATURATION PROPERTIES FOR FM-200

TEMP (F)	PRESSURE (PSIA)	DENSITY (LB/FT**3)		ENTHALPY (BTU/LB)			ENTROPY (BTU/LB F)		CV		CP	
		LIQ	VAP	LIQ	EVAP	VAP	LIQ	VAP	LIQ	VAP	LIQ	VAP
-40	4.639	100.03	0.1787	0.0	61.1	61.1	0.0000	0.1456	0.1985	0.1248	0.2172	0.1375
-35	5.388	99.50	0.2056	1.1	60.7	61.8	0.0026	0.1454	0.2005	0.1264	0.2192	0.1393
-30	6.231	98.97	0.2356	2.2	60.2	62.4	0.0052	0.1453	0.2025	0.1280	0.2211	0.1410
-25	7.178	98.43	0.2691	3.3	59.7	63.1	0.0077	0.1452	0.2044	0.1296	0.2231	0.1428
-20	8.237	97.89	0.3062	4.4	59.3	63.7	0.0103	0.1451	0.2063	0.1312	0.2250	0.1445
-15	9.418	97.35	0.3473	5.6	58.8	64.4	0.0128	0.1451	0.2082	0.1328	0.2270	0.1463
-10	10.730	96.81	0.3927	6.7	58.3	65.0	0.0154	0.1451	0.2101	0.1344	0.2289	0.1481
-5	12.183	96.27	0.4427	7.8	57.8	65.7	0.0179	0.1451	0.2120	0.1359	0.2308	0.1500
0	13.788	95.72	0.4977	9.0	57.3	66.3	0.0205	0.1452	0.2139	0.1375	0.2328	0.1518
5	15.556	95.17	0.5579	10.2	56.8	67.0	0.0230	0.1452	0.2157	0.1391	0.2347	0.1537
10	17.497	94.62	0.6237	11.4	56.3	67.6	0.0255	0.1454	0.2175	0.1406	0.2367	0.1556
15	19.624	94.06	0.6956	12.5	55.8	68.3	0.0280	0.1455	0.2193	0.1422	0.2386	0.1575
20	21.947	93.50	0.7739	13.7	55.2	69.0	0.0305	0.1456	0.2211	0.1438	0.2405	0.1595
25	24.480	92.93	0.8591	15.0	54.7	69.6	0.0330	0.1458	0.2228	0.1454	0.2425	0.1615
30	27.233	92.36	0.9516	16.2	54.1	70.3	0.0355	0.1460	0.2246	0.1469	0.2444	0.1635
35	30.221	91.78	1.0518	17.4	53.5	70.6	0.0380	0.1462	0.2263	0.1485	0.2464	0.1656
40	33.456	91.20	1.1603	18.6	52.9	71.6	0.0405	0.1464	0.2280	0.1501	0.2484	0.1677
45	36.951	90.61	1.2776	19.9	52.3	72.2	0.0429	0.1467	0.2296	0.1517	0.2503	0.1699
50	40.720	90.02	1.4042	21.2	51.7	72.9	0.0454	0.1469	0.2313	0.1533	0.2523	0.1722
55	44.775	89.42	1.5406	22.4	51.1	73.5	0.0479	0.1472	0.2329	0.1549	0.2543	0.1745
60	49.132	88.81	1.6876	23.7	50.5	74.2	0.0503	0.1475	0.2345	0.1565	0.2563	0.1769
65	53.804	88.20	1.8458	25.0	49.8	74.8	0.0528	0.1477	0.2361	0.1581	0.2583	0.1793
70	58.804	87.58	2.0157	26.3	49.2	75.4	0.0552	0.1480	0.2377	0.1597	0.2604	0.1819
75	64.148	86.95	2.1982	27.6	48.5	76.1	0.0577	0.1483	0.2392	0.1614	0.2625	0.1846
80	69.850	86.31	2.3941	28.9	47.8	76.7	0.0601	0.1486	0.2407	0.1630	0.2646	0.1873
85	75.925	85.66	2.6041	30.2	47.1	77.3	0.0625	0.1489	0.2422	0.1647	0.2667	0.1902
90	82.386	85.00	2.8291	31.6	46.3	77.9	0.0649	0.1492	0.2436	0.1664	0.2689	0.1932
95	89.249	84.33	3.0700	32.9	45.6	78.5	0.0674	0.1495	0.2451	0.1680	0.2711	0.1964
100	96.528	83.65	3.3279	34.3	44.8	79.1	0.0698	0.1498	0.2465	0.1698	0.2734	0.1997
105	104.239	82.95	3.6039	35.7	44.0	79.7	0.0722	0.1501	0.2478	0.1715	0.2757	0.2034
110	112.395	82.25	3.8990	37.0	43.2	80.3	0.0746	0.1504	0.2492	0.1733	0.2781	0.2069
115	121.011	81.53	4.2145	38.4	42.4	80.8	0.0770	0.1507	0.2505	0.1750	0.2806	0.2108
120	130.103	80.79	4.5518	39.8	41.5	81.4	0.0794	0.1510	0.2518	0.1768	0.2832	0.2150
125	139.684	80.04	4.9122	41.3	40.7	81.9	0.0818	0.1513	0.2530	0.1787	0.2859	0.2194
130	149.768	79.28	5.2975	42.7	39.8	82.5	0.0842	0.1516	0.2543	0.1805	0.2887	0.2242
135	160.371	78.50	5.7092	44.1	38.9	83.0	0.0866	0.1519	0.2554	0.1824	0.2916	0.2293
140	171.505	77.69	6.1493	45.6	37.9	83.5	0.0889	0.1522	0.2566	0.1844	0.2948	0.2349
145	183.184	76.87	6.6198	47.0	37.0	84.0	0.0913	0.1524	0.2577	0.1864	0.2981	0.2409
150	195.422	76.03	7.1230	48.5	36.0	84.5	0.0937	0.1527	0.2588	0.1884	0.3017	0.2474
155	208.231	75.16	7.6614	50.0	35.0	85.0	0.0961	0.1529	0.2598	0.1904	0.3056	0.2546
160	221.625	74.27	8.2377	51.5	33.9	85.4	0.0985	0.1532	0.2608	0.1925	0.3099	0.2625

TABLE 10. SUPERHEATED VAPOR PROPERTIES FOR FM-200

PRESSURE = 14.70 PSIA

	TEMP (F)	DENSITY (LB/FT**3)	ENTHALPY (BTU/LB)	ENTROPY -----	CV (BTU/LB F)	CP -----
SATLIQ	2.6	95.4325	9.6	0.0218	0.2148	0.2338
SATVAP	2.6	0.5286	66.7	0.1452	0.1383	0.1528
	10.0	0.5190	67.8	0.1476	0.1405	0.1549
	20.0	0.5065	69.4	0.1509	0.1435	0.1577
	30.0	0.4947	71.0	0.1542	0.1465	0.1605
	40.0	0.4835	72.6	0.1575	0.1494	0.1633
	50.0	0.4728	74.2	0.1607	0.1523	0.1660
	60.0	0.4626	75.9	0.1640	0.1551	0.1688
	70.0	0.4529	77.6	0.1672	0.1579	0.1715
	80.0	0.4436	79.3	0.1705	0.1607	0.1742
	90.0	0.4348	81.1	0.1737	0.1635	0.1768
	100.0	0.4263	82.9	0.1769	0.1662	0.1795
	110.0	0.4181	84.7	0.1801	0.1689	0.1821
	120.0	0.4103	86.5	0.1833	0.1715	0.1846
	130.0	0.4028	88.4	0.1865	0.1742	0.1872
	140.0	0.3956	90.3	0.1896	0.1767	0.1897
	150.0	0.3886	92.2	0.1928	0.1793	0.1922
	160.0	0.3819	94.1	0.1960	0.1818	0.1947
	170.0	0.3755	96.1	0.1991	0.1843	0.1971
	180.0	0.3693	98.0	0.2022	0.1868	0.1995
	190.0	0.3633	100.0	0.2053	0.1892	0.2019
	200.0	0.3575	102.1	0.2084	0.1916	0.2042
	210.0	0.3519	104.1	0.2115	0.1940	0.2065
	220.0	0.3464	106.2	0.2146	0.1963	0.2088
	230.0	0.3412	108.3	0.2177	0.1986	0.2111
	240.0	0.3361	110.4	0.2207	0.2009	0.2133
	250.0	0.3312	112.6	0.2238	0.2031	0.2155
	260.0	0.3264	114.7	0.2268	0.2053	0.2177
	270.0	0.3218	116.9	0.2298	0.2075	0.2198
	280.0	0.3173	119.1	0.2328	0.2096	0.2219
	290.0	0.3129	121.4	0.2358	0.2117	0.2240
	300.0	0.3086	123.6	0.2388	0.2138	0.2260
	310.0	0.3045	125.9	0.2418	0.2158	0.2280
	320.0	0.3005	128.2	0.2447	0.2178	0.2300
	330.0	0.2966	130.5	0.2477	0.2198	0.2320
	340.0	0.2928	132.8	0.2506	0.2218	0.2339
	350.0	0.2891	135.2	0.2535	0.2237	0.2358
	360.0	0.2855	137.5	0.2564	0.2256	0.2376
	370.0	0.2820	139.9	0.2593	0.2274	0.2395
	380.0	0.2786	142.3	0.2622	0.2292	0.2412
	390.0	0.2752	144.7	0.2651	0.2310	0.2430
	400.0	0.2720	147.2	0.2679	0.2328	0.2447

TABLE 11. FM-200 TOTAL FLOODING QUANTITY

TEMP -t- (°F) [2]	FM-200 Specific Vapor Volume -s- (cu.ft./lb) [3]	FM-200 Weight Requirements of Hazard Volume W/V (lb/cu.ft.) [1]									
		FM-200 Concentration (% by volume) [4]									
10	1.9264	0.0331	0.0391	0.0451	0.0513	0.0577	0.0642	0.0708	0.0776	0.0845	0.0916
20	1.9736	0.0323	0.0381	0.0441	0.0501	0.0563	0.0626	0.0691	0.0757	0.0825	0.0894
30	2.0210	0.0316	0.0372	0.0430	0.0489	0.0550	0.0612	0.0675	0.0739	0.0805	0.0873
40	2.0678	0.0309	0.0364	0.0421	0.0478	0.0537	0.0598	0.0659	0.0723	0.0787	0.0853
50	2.1146	0.0302	0.0356	0.0411	0.0468	0.0525	0.0584	0.0645	0.0707	0.0770	0.0835
60	2.1612	0.0295	0.0348	0.0402	0.0458	0.0514	0.0572	0.0631	0.0691	0.0753	0.0817
70	2.2075	0.0289	0.0341	0.0394	0.0448	0.0503	0.0560	0.0618	0.0677	0.0737	0.0799
80	2.2538	0.0283	0.0334	0.0386	0.0439	0.0493	0.0548	0.0605	0.0663	0.0722	0.0783
90	2.2994	0.0278	0.0327	0.0378	0.0430	0.0483	0.0538	0.0593	0.0650	0.0708	0.0767
100	2.3452	0.0272	0.0321	0.0371	0.0422	0.0474	0.0527	0.0581	0.0637	0.0694	0.0752
110	2.3912	0.0267	0.0315	0.0364	0.0414	0.0465	0.0517	0.0570	0.0625	0.0681	0.0738
120	2.4366	0.0262	0.0309	0.0357	0.0406	0.0456	0.0507	0.0560	0.0613	0.0668	0.0724
130	2.4820	0.0257	0.0303	0.0350	0.0398	0.0448	0.0498	0.0549	0.0602	0.0656	0.0711
140	2.5272	0.0253	0.0298	0.0344	0.0391	0.0440	0.0489	0.0540	0.0591	0.0644	0.0698
150	2.5727	0.0248	0.0293	0.0338	0.0384	0.0432	0.0480	0.0530	0.0581	0.0633	0.0686
160	2.6171	0.0244	0.0288	0.0332	0.0378	0.0425	0.0472	0.0521	0.0571	0.0622	0.0674
170	2.6624	0.0240	0.0283	0.0327	0.0371	0.0417	0.0464	0.0512	0.0561	0.0611	0.0663
180	2.7071	0.0236	0.0278	0.0321	0.0365	0.0410	0.0457	0.0504	0.0552	0.0601	0.0652
190	2.7518	0.0232	0.0274	0.0316	0.0359	0.0404	0.0449	0.0496	0.0543	0.0592	0.0641
200	2.7954	0.0228	0.0269	0.0311	0.0354	0.0397	0.0442	0.0488	0.0535	0.0582	0.0631

[1] - W/V [Agent Weight Requirements (lb/cu.ft.)] - Pounds of agent per cubic foot of protected volume to produce indicated concentration at temperature specified.

$$W = \frac{V}{s} \frac{C}{100 - C}$$


[2] t [Temperature (F)] - The design temperature in the hazard area.

[3] s [Specific Volume (cu.ft./lb)] - Specific volume of superheated FM-200 vapor may be approximated by the formula:

$$s = 1.8854 + 0.004574t$$

where t = temperature (F)

[4] C [Concentration(%)] - Volumetric concentration of FM-200 in air at the temperature indicated.



Experimental data for FM-100 and FM-200 were fit to the Carnahan-Starling-DeSantis equation of state. Tables of saturation properties and superheated vapor properties were generated, and pressure-enthalpy diagrams constructed. More details of this work were not included due to space constraints. Other properties of interest such as saturated and superheated vapor properties of FM-100 and Halons 1301 and 1211, transport properties, etc., are available upon request.

ACKNOWLEDGMENT

The measurement of the PVT properties of FM-100 and FM-200 by Professor W. Alexander Van Hook and coworkers at the University of Tennessee, Knoxville, is gratefully acknowledged.

REFERENCES

1. Robin, M.L., "Evaluation of Halon Alternatives," Proceedings of the Halon Alternatives Technical Working Conference, Albuquerque, NM, April 30 - May 1, 1991.
2. Robin, M.L., "FM-100: An Efficient Halon Alternative for Use in Portable and Total Flooding Fire Extinguishing Systems," ACS 10th Winter Fluorine Conference, St. Petersburg, FL, January 29 - February 2, 1991.
3. Skaggs, S.R., Heinonen, E.W., Tapscott, R.E. and Smith, N.D., "Research and Development for Total Flood Halon 1301 Replacements for Oil and Gas Production Facilities at the Alaskan North Slope," 1991 International CFC and Halon Alternatives Conference, Baltimore, MD, December 3-5, 1991.
4. Ford, C.L., "Extinguishment of Surface and Deep-seated Fires With Halon 1301," in An Appraisal of Halogenated Fire Extinguishing Agents, National Academy of Sciences, Washington, D.C., 1972, p. 158.
5. Yamashika, S., "Dependence of Extinction Time and Decomposition of Halogenated Extinguishing Agent on Its Application Rate," Ibid., p. 326.
6. Kay, D.H., "Design, Test and Evaluation of Total Coverage Fixed Fire Extinguishing Systems for Machinery Spaces," Naval Ship Engineering Center Report of 12, February, 1973, NAVSEA 0993-LP-030-5010,
7. Hill, R., "Evaluation of a Halon 1301 System for Aircraft Internal Protection From a Postcrash External Fuel Fire," Federal Aviation Administration Report, FAA-76-218, March 1977.
8. Sheinson, R.S. and Alexander, J.I., "HF and HBr From Halon 1301 Extinguished Pan Fires," 1982 Fall Technical Meeting Proceedings Chemical and Physical Processes in Combustion, Eastern Section Combustion Institute, Atlantic City, NJ, December 14-16, 1982.
9. Sheinson, R.S., Musick, J.K. and Carhart, H.W., Fire and Flamm., 12,229 (1981).
10. Robin, M.L., "Large Scale Testing of Halon Alternatives," 1991 International CFC and Halon Alternatives Conference, Baltimore, MD, December 3-5, 1991.
11. Anderson, R.F. and Punderson, J.O., in Organofluorine Chemicals and Their Industrial Applications, R.E. Banks, ed., Ellis Horwood, London, 1979, p. 235.
12. Purser, D.A., "Toxicity Assessment," in SEPE Handbook of Fire Protection Engineering.
13. Taylor, G., "Halogenated Agents and Systems," in Fire Protection Handbook, NFPA, Quincy, MA, 1991, p. 5-241.
14. Salvi-Narkhede, M., Wang, B., Adcock, J.L. and Van Hook, W.A., J. Chem Thermodynam., in press.
15. Salvi, M. and Van Hook, W.A., J. Phys. Chem., 94,7812 (1990).
16. du Pont Technical Bulletin T-1301.

17. ICI, BCF (Halon **1211**) Systems Design Manual.
18. **Smith, J.M. and Van Ness, H.C., Introduction to Chemical Engineering Thermodynamics, 4th ed., McGraw-Hill, NY, 1987, p. 89ff.**
19. Momson, G. and McLinden, M., "Application of a Hard Sphere Equation of State to Refrigerants and Refrigerant Mixtures," NBS Technical Note **1226 (1986)**.
20. Morrison, G. and Gallagher, J.S., "REFPROP: A Thermodynamic Properties Software Program for Refrigerants and Their Mixtures," Proceedings USNC/IR-Purdue Refrigeration Conference, July **17-20, 1990**, p. **242**.
21. NIST Standard Reference Database **23: NIST Thermodynamic Properties of Refrigerants and Refrigerant Mixtures Database, Version 2.0, NIST, 1991**.
22. Kudchadker, S.A and Kudchadker, A.P., J. Phys. Chem. Ref. Data, **7(4), 1285 (1978)**.
23. Perry's Chemical Engineer's Handbook, 6th ed., **1984**.