

Amendment SB134118RQ0199/0001

The purpose of this amendment is to respond to interested vendor's question as follows:

Question 1.

The Solicitation lists the quantity of the total batteries for the Eaton 9315-400-500 (serial ED411BAA01) as 200 but the manufacturer's records state quantity as 240 batteries. Can you clarify which count is correct please?

Answer 1.

There are only 200 batteries, although there are six battery banks initially installed, there are only five in use and in fact not wired to use the 6th.