

STATUS REPORT

DEVELOPMENT OF WATER MIST SYSTEMS FOR US NAVY SHIPBOARD MACHINERY SPACES

**Robert L. Darwin (Naval Sea Systems Command)
Joseph T. Leonard (Naval Research Laboratory)
Gerald G. Back (Hughes Associates, Inc.)**

**Presented at the Halon Options Technical Working Conference,
Albuquerque, NM, 09-11 May 1995**

WATER MIST FIRE EXTINGUISHING SYSTEMS

ADVANTAGES

- **ZERO OZONE DEPLETION POTENTIAL**
- **ZERO GLOBAL WARMING POTENTIAL**
- **NON TOXIC**
- **NON CORROSIVE (IF MADE FROM POTABLE WATER)**
- **TREMENDOUS COOLING CAPACITY**

WATER MIST FIRE EXTINGUISHING SYSTEM R&D APPROACH - OVERVIEW

- **SMALL SCALE FIRE SUPPRESSION STUDIES WERE CONDUCTED TO DETERMINE OPTIMUM SYSTEM PARAMETERS FOR SUPPRESSION OF CLASS A AND CLASS B FIRES, \approx G:

TWO FLUID VS HIGH PRESSURE SYSTEM

DROPLET SIZE

MOMENTUM

CONCENTRATION, ETC.**
- **LARGE SCALE TESTS ARE BEING CONDUCTED IN SIMULATED MACHINERY SPACE TO VERIFY SYSTEM DESIGN AND PERFORMANCE**







Fig. 2 - Test fire scenarios


WATER MIST FIRE EXTINGUISHING SYSTEMS

SUMMARY OF SMALL SCALE TESTS AT CBQ


- **OVER 730 FIRE TESTS WERE CONDUCTED**
- **TWO TYPES OF SYSTEMS WERE TESTED: DUAL FLUID AND SINGLE FLUID (LOW AND HIGH PRESSURE)**
- **ALL SYSTEMS TESTED EXTINGUISHED OVER 85% OF THE SPRAY AND UNOBSTRUCTED PAN FIRES**
- **SPRAY FIRES WERE EASIEST TO EXTINGUISH - USUALLY WITHIN 10 SECONDS. PAN FIRES REQUIRED ABOUT 1 MINUTE FOR EXTINGUISHMENT**
- **OBSTRUCTED (HIDDEN) FIRES WERE DIFFICULT-TO-IMPOSSIBLE TO EXTINGUISH, DEPENDING ON THE SYSTEM**

WATER MIST FIRE EXTINGUISHING SYSTEM


NOZZLE SYSTEMS TESTED ON EX-USS SHADWELL




Grinnell
200 psi
94 gpm



Baumac
1350 psi
72 gpm



Modified
SPRAYING SYSTEMS
1500 psi
58 gpm



Marioff
3000 ps
58 gpm

WATER MIST FIRE EXTINGUISHING SYSTEM

FIRE SCENARIOS

- 29 "TELL TALE" HEPTANE PAN FIRES
- HEPTANE PAN FIRES (1 FOOT SQUARE)
- SPRAY FIRE (250 kW) - SHIELDED
- SPRAY FIRE (2.5 - 6.5 MW) - UNSHIELDED

An additional test was conducted using the modified Spraying Systems nozzles against a 10 MW Fire


WATER MIST TESTS ON EX-USS SHADWELL

- **PHASE I:**
 - UNOBSTRUCTED MACHINERY SPACE
 - NOZZLES INSTALLED IN OVERHEAD ONLY

- **PHASE II:**
 - OBSTRUCTED MACHINERY SPACE
 - NOZZLES INSTALLED IN OVERHEAD ONLY
 - NOZZLES INSTALLED AT TWO LEVELS (AS IN HALON INSTALLATIONS)

- **PHASE III:**
 - OPTIMIZED SYSTEM (4Q95)
 - NOZZLES INSTALLED AT TWO LEVELS

Machinery Space Obstructions (Elevation View)




FULL SCALE TEST RESULTS - MODIFIED COMMERCIAL NOZZLE

Scenario	Extinguishment Time (min:sec)		
System	Modified Commercial Nozzle		
Nozzle Pressure	105 bar (1500 psi)	105 bar (1500 psi)	
System Flow Rate	225 Lpm (58 gpm)	166 Lpm (44 gpm)	
Application Rate	1.34 Lpm/m ² 0.032 gpm/ft ²	2.03 Lpm/m ² 0.050 gpm/ft ²	
Space Nozzle Location	Unobstructed Space	Obstructed Space	
	Single Level	Single Level	Bi-Level
Scenario #2 (4.5 MW)* Fire #1 Fire #2 Fire #3 Fire #5	2:00 1:15 1:30 2:15	1:45 1:27 0:40 1:30	0:20 0:20 0:20 0:20
Scenario #4 (7.5 MW)* Fire #1 Fire #2 Fire #3 Fire #5	1:30 1:00 0:45 1:00	1:20 1:25 0:50 1:15	0:20 0:15 0:20 0:25
Scenario #5 (7.5 MW)** Fire #1 Fire #2 Fire #3 Fire #5	3:45 No No 2:00	2:30 NO 0:20 1:15	0:40 NO 0:40 0:50

* - Ventilation (exhaust and supply) was secured during mist system activation.

** - Ventilation (exhaust and supply) remained operating during this test



WATER MIST FIRE EXTINGUISHING SYSTEM

FUTURE PLANS

- **INTERMEDIATE SCALE TESTS TO OPTIMIZE PERFORMANCE OF SYSTEM**
- **SHIP IMPACT STUDY TO IDENTIFY OPTIONS FOR INSTALLING WATER MIST SYSTEMS ON I.P.D.-17 CLASS SHIPS**
- **FULL SCALE TESTS OF OPTIMIZED, FULL-SPEC WATER MIST SYSTEMS ON EX-USS SHADWELL**