

# F-15 Halon Replacement Trade Study

Glenn DuBrucq (314) 233-1744

1996 Halon Options Technical Working Conference  
09 May 1996  
Albuquerque, NM

Sponsored by F-15 SPO



## Baseline System

- One 6.6 pound Halon 1301 bottle mounted between engines
- System weighs 21 pounds
- Four bays protected (3 fire zones)
  - Right/Left Engine
  - JFS/AMAD bays
- Bottle and system design and qualification based on Mil-E-22285
- DoD Halon bank supporting F-15 fleet



# Performance Requirements

- Two fundamental performance requirements
  - Minimum agent required defined by design equations (volume and ventilation)
  - Agent concentration must be 6% for 0.5 secs simultaneously throughout bay
- Concentration tests in engine nacelle verify system performance

MCDONNELL DOUGLAS



# The Candidates

- Three candidate replacements down selected for study
  - HFC-125 (Fe-25,  $C_2HF_5$ )
  - $CF_3I$  (Triiodide, Iodoguard)
  - Gas Generators
- Baseline: Halon 1301  $CF_3Br$

MCDONNELL DOUGLAS



## HFC-125

- Selected by DoD, FAA as agent for near term development
- Test effort at Wright Labs is determining amount of agent needed
  - Design equations
  - Concentration vs. time profile
  - DoD meeting in January to review results
- Selected by V-22 for engine nacelle fire protection

MCDONNELL DOUGLAS



## HFC-125 Issues

- Total weight = 41 pounds (at 2.1 x Halon volume)
  - Cylindrical bottle needed
- Adequate dispersion at all operating temperatures
  - Additional discharge nozzle may be needed
- Maintenance similar to Halon
- Toxicity - Approved only for normally unoccupied areas
- Material compatibility acceptable
- Qualification similar to Halon

MCDONNELL DOUGLAS




# CF<sub>3</sub>I

- Advertised as drop-in replacement
  - Volume competitive with Halon
- Commercial aircraft most interested
- FAA plans on determining required concentration profile in early 1996
  - Fire tests, concentration measurements

MCDONNELL DOUGLAS 

## CF<sub>3</sub>I Design Configuration

- Existing data suggests volume equal to Halon
  - System weight 26 pounds
- CF<sub>3</sub>I probably not drop-in replacement for F-15
  - Additional discharge nozzle in upper forward portion of bay
- Material compatibility, stability acceptable
- Maintenance, qualification similar to Halon

MCDONNELL DOUGLAS 

## CF<sub>3</sub>I Toxicity

- NOAEL an order of magnitude lower than Halon 1301, HFC-125
- Data based on exposure times of about 15 minutes
- Maintenance crew exposure likely to be seconds
  - Personnel can evacuate
  - CF<sub>3</sub>I will concentrate at ground level
- No data on short times, high concentration levels
- MDA experts feel physical injury more likely than chemical injury
  - Common to all agents

MCDONNELL DOUGLAS



## CF<sub>3</sub>I Dispersion at Cold Temperatures

- Boiling point -8°F at sea level
- Test data shows adequate dispersion with cold bottle in ambient bay
- Dispersion, vaporization in cold bay questionable
- How critical is performance at -20°F on ground?
  - Ground crew often extinguish these fires
  - Extra agent may compensate

MCDONNELL DOUGLAS



# Gas Generators

- Derived from automobile air bag technology
- Selected by F/A-18 E/F for engine nacelle protection
- USAF plans to flight certify KC-135 system
- Extinguishing mechanism not fully understood
  - Inerting vs. blow out

*MCDONNELL DOUGLAS*

## Gas Generator Design Configuration

- Propellant burns for 6 seconds
  - Long burn time prevents relight
- System weight 29 pounds
  - Additional nozzle in forward, upper nacelle
- Engine cleanup may be required after use
  - Solids expelled
- 5.5 year service life
  - Same as electrical initiators

*MCDONNELL DOUGLAS*



# Gas Generator Qualification

- F/A-18 €F
  - Building and extinguishing fires to qualify
  - Nacelle simulator withstands many fires
  - Determined baseline fire location, strength
    - Limit of Halon system
  - Will attempt to measure concentration vs. time
- Assuming F-15 will need to build fires




## Summary

	Halon 1301	HFC-125	CF <sub>3</sub> I	Gas Gen
Weight (lbs)	21	41	26	29
Dist Sys	-	(Add discharge nozzle for all options)		
Qualification	-	Conc test	Conc test	Fire test
LC Cost (\$x10 <sup>-6</sup> )	5	17	14	40
Risks	Minor	Bank viability	Weight	Toxicity
			Material comp	-

Moderate

Low temp performance

Extinguishing mechanism



## Conclusions/Recommendations

- Gas generators too expensive
  - No strong advantages to overcome cost
- HFC-125 acceptable
  - Best knowledge base
  - **Better low temperature performance** than CF<sub>3</sub>I
- CF<sub>3</sub>I has marginal advantages over HFC-125
  - Easiest retrofit, Minimum cost/weight
  - **Issues: Low temperature performance, toxicity**
- Pending WPAFB test results may change conclusions
- There is no pressing need to change from Halon

MCDONNELL DOUGLAS

